



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SiH	Y/N
1					
2					
3	7.7				Y
4					
5	7.7				Y
6					
7					
8					
9					
10	7.6				Y
11					
12	7.6				Y
13					
14					
15					
16					
17	7.6				Y
18					
19	7.7				Y
20					
21					
22					
23	7.7				Y
24					
25					
26	7.7				Y
27					
28					
29					
30					
31	7.6				Y

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP-8

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: Dec 2024

Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Zach Forcier

Signature: [Signature]

Date/Phone#: 1/10/25 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

(No = N = Excursion) Total N's 0

**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>**