

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1						minimums
2						been met for this day? PWS ID: 41 0 0 9 2 5
3	7.6				Y	System Name: System Name:
4						System Name: 20 Cincil Co Vater V
5						Entry Point: EP-B
6						Sample Period: 2005
7						Month/Year
8	7.7				У	Number of excursions* during this month: O
9						(Count the number of days when any WQP was
10	7.8				У	less than the minimum required)
11						
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						For OHA use only
16						
17						Minimum Water Quality
18	7.8				Y	Parameters as set by
19						рН 7./
20						Alk (Alkalinity)
21						PO4 (Orthophosphate)
22	7.6				У	Other ()
23			-			
24					1/	
25	7.7		-	-	У	
26			-	-		2 × mall
27	-		-			Print Name: Sich III Olung
28	_					Signature: L. M. Cluner
29			-			Date: 5/9/25 0
30	-		-			Send to DWP within 10 days after end of
31	<u> </u>		\			sampling period
1 = oN	A = Exc	cursion	n) Tota			

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/