



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1	7.3				Y
2					
3					
4					
5	7.4				Y
6					
7	7.5				Y
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20	7.3				Y
21					
22					
23					
24					
25					
26					
27					
28	7.4				Y
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- B

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: August 2025

Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: R. McCLARY

Signature: R. McCLARY

Date Phone#: 9/3/25 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

(No = N = Excursion) **Total N's** 0

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>