



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					
2	7.7				Y
3					
4					
5					
6	7.5				Y
7					
8					
9	7.7				Y
10					
11					
12					
13					
14					
15					
16					
17					
18	7.5				Y
19					
20	7.6				Y
21					
22					
23					
24					
25	7.5				Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**

**EP- B**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

**Sample period:** February 2026

Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

**Print Name:** Rick McClung

**Signature:** [Signature]

**Date Phone#:** 2/28/26 541-547-3315

**Send to DWP within 10 days after end of sampling period**

(No = N = Excursion) **Total N's** 0