



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7				Y
2	7.7				Y
3	7.7				Y
4	7.8				Y
5	7.8				Y
6					
7					
8	7.8				Y
9	7.9				Y
10	7.8				Y
11	7.8				Y
12	7.9				Y
13					
14					
15					
16	7.6				Y
17	7.6				Y
18	7.5				Y
19	7.8				Y
20	7.7				Y
21	7.8				Y
22	7.8				Y
23	7.7				Y
24	7.8				Y
25	7.8				Y
26	7.8				Y
27	7.8				Y
28	7.8				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP-A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: February 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference

Data Mgmt & Compliance
Drinking Water Program

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: BARRY ARNOLD

Signature: Barry Arnold

Date Phone#: 3-3-21 541-547-4951

Send to DWP within 10 days after end of sampling period

(No. = N = Excursion) Total N's 0