



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.6				Y
3	7.7				Y
4	7.7				Y
5	7.8				Y
6					
7	7.8				Y
8	7.6				Y
9	7.7				Y
10	7.7				Y
11	7.8				Y
12	7.8				Y
13					
14					
15	7.7				Y
16	7.6				Y
17					
18	7.4				Y
19	7.8				Y
20					
21					
22	7.7				Y
23	7.5				X
24	7.7				Y
25	7.7				Y
26	7.5				X
27					
28					
29	7.6				Y
30	7.6				Y
31	7.7				Y

County: Lincoln Agency: REGION 2
ENTRY POINT
EP-A
PWS ID 4100925
SW LINCOLN CO WATER DIST
 Sample period: MARCH 2021
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED

APR 07 2021

Data Mgmt & Compliance
Drinking Water Program

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: BARRY ARNOLD
 Signature: Barry Arnold
 Date Phone#: 4-5-21 541-547-3315
 Send to DWP within 10 days after end of sampling period

(No. = N = Excursion) Total N's 0