



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3					
4	7.8				Y
5	7.8				Y
6	7.8				Y
7	7.6				Y
8					
9					
10	7.5				Y
11	7.6				Y
12	7.7				Y
13	7.7				Y
14	7.7				Y
15					
16					
17	7.6				Y
18	7.8				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22					
23					
24	7.6				Y
25					
26					
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.4				Y
31	7.5				Y

<<Have minimums been met for this day?

County: Lincoln    Agency: REGION 2

### ENTRY POINT

#### EP-A

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

**Sample period:** MAY 2021

Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Data Mgmt & Compliance  
Drinking Water Program

**Print Name:** BARRY ARNOLD

**Signature:** Barry Arnold

**Date Phone#:** 6-9-21 541-547-3315

Send to DWP within 10 days after end of sampling period

(No. = N = Excursion) **Total N's** 0