



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.6				Y
3	7.5				Y
4	7.5				Y
5	7.6				Y
6	7.4				Y
7					
8					
9	7.3				Y
10	7.4				Y
11	7.3				Y
12	7.5				Y
13	7.4				Y
14					
15					
16	7.5				Y
17	7.6				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21					
22					
23	7.8				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28					
29					
30	7.4				Y
31	7.4				Y

<<Have minimums been met for this day?

County: Lincoln    Agency: REGION 2

### ENTRY POINT

#### EP-A

#### PWS ID 4100925

#### SW LINCOLN CO WATER DIST

Sample period: August 2021  
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

**Print Name:** BARRY ARNOLD

**Signature:** Barry Arnold

**Date Phone#:** 9-2-21 541-547-4951

Send to DWP within 10 days after end of sampling period

(No. = N = Excursion) **Total N's** 0