



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8				Y
2	7.4				Y
3	7.8				Y
4					
5					
6	7.8				Y
7					
8					
9	7.8				Y
10					
11					
12	7.8				Y
13	7.8				Y
14					
15					
16					
17					
18	7.9				Y
19	7.9				Y
20	7.8				Y
21	7.8				Y
22	7.8				Y
23	7.7				Y
24	7.8				Y
25					
26					
27					
28					
29	7.9				Y
30	7.9				Y
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**  
**EP-A**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

Sample period: November 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: BARRY ARNOLD

Signature: Barry Arnold

Date Phone#: 12-9-21 541-547-3315

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0