



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1					
2					
3					
4	7.8				Y
5	8.0				Y
6	7.8				Y
7	7.9				Y
8	7.5				Y
9	7.6				Y
10	7.8				Y
11	7.8				Y
12	7.7				Y
13					
14	7.8				Y
15					
16	7.9				Y
17	7.7				Y
18					
19					
20	7.6				Y
21	7.6				Y
22	7.8				Y
23					
24	7.8				Y
25	7.7				Y
26	7.8				Y
27	7.7				Y
28	7.7				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

ENTRY POINT
EP-A

PWS ID 4100925
SW LINCOLN CO WATER DIST

Sample period: January 1 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: BARRY ARNOLD
Signature: Barry Arnold
Date Phone#: 2-1-22 541-547-3315

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0