



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3	7.6				Y
4	7.5				Y
5	7.6				Y
6	7.5				Y
7					
8					
9	7.8				Y
10	7.8				Y
11	7.6				Y
12	7.8				Y
13					
14					
15					
16	7.6				Y
17	7.5				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21					
22					
23					
24	7.5				Y
25	7.5				Y
26	7.5				Y
27	7.4				Y
28					
29	7.5				Y
30	7.4				Y
31	7.5				Y

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**  
**EP-A**

**PWS ID 4100925**  
**SW LINCOLN CO WATER DIST**

Sample period: MAY 2022  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**  
pH 7.1

Print Name: BARRY ARNOLD  
Signature: Barry Arnold  
Date Phone#: 6-8-22 541-547-3315

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0