



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.4				Y
5	7.4				Y
6					
7					
8					
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13					
14					
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20					
21					
22	7.3				Y
23	7.3				Y
24	7.3				Y
25	7.4				Y
26	7.4				Y
27					
28					
29	7.5				Y
30	7.5				Y
31	7.5				Y

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**

**EP-A**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

**Sample period:** August 2022  
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

**Print Name:** ~~BARRY ARNOLD~~ Rick McElroy

**Signature:** ~~BARRY ARNOLD~~ 2725

**Date Phone#:** 541-547-3315

**Send to DWP within 10 days after end of sampling period**

(No = N = Excursion) **Total N's** 0