



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3					
4	7.7				Y
5					
6					
7					
8	7.7				Y
9					
10					
11	7.7				Y
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.9				Y
26					
27					
28					
29	7.8				Y
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP-B

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: January 2021
Month/Year

RECEIVED

FEB 11 2021

Data Mgmt & Compliance
Drinking Water Program

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: BARRY ARNOLD

Signature: Barry Arnold

Date Phone#: 2-4-21 541-547-4951

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0