



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3	7.6				Y
4					
5	7.6				Y
6					
7	7.6				Y
8					
9					
10					
11					
12	7.5				Y
13					
14	7.5				Y
15					
16					
17	7.6				Y
18					
19	7.6				Y
20	7.6				Y
21	7.6				Y
22					
23					
24	7.6				Y
25					
26					
27	7.6				Y
28					
29					
30	7.4				Y
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT  
EP-B**

**PWS ID 4100925  
SW LINCOLN CO WATER DIST**

Sample period: MAY 2021  
Month/Year

Number of excursions during this month: 6

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

RECEIVED

JUN 11 2021

Data Mgmt & Compliance  
Drinking Water Program

Print Name: BARRY ARNOLD

Signature: Barry Arnold

Date Phone#: 6-9-21 541-547-3315

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 6