



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.4				Y
3					
4					
5					
6	7.4				Y
7					
8	7.5				Y
9	7.4				Y
10					
11					
12	7.4				Y
13					
14	7.5				Y
15					
16	7.5				Y
17					
18					
19	7.4				Y
20					
21	7.4				Y
22					
23	7.4				Y
24					
25					
26	7.4				Y
27	7.4				Y
28					
29	7.4				Y
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**

**EP-B**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

Sample period: July 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: BARRY ARNOLD

Signature: Barry Arnold

Date Phone#: 8-3-21 541-547-3315

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0