



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2					
3	7.7				Y
4					
5					
6					
7					
8					
9	7.6				Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

ENTRY POINT
EP-B

PWS ID 4100925
SW LINCOLN CO WATER DIST

Sample period: December, 2021
Month/Year



Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: BARRY ARNOLD
Signature: Barry Arnold
Date Phone#: 1-7-22

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 8