JULY 2022

BL

DHS / OHD
oregon department of human services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Sili	Y/N
7-1	Blodget	7.8	20			Y
7-5		7.8	20			Y
7-6		7.8	20			Y
7-7		7.8	20			Y
7-8		7.7	20			Y
7-12		7.7	20			Y
7-13		7.5	20			Y
7-14		7.5	20			Y
7-15		7.7	20			Y
7-16		7.7	20			Y
7-18		7.6	20			Y
7-19		7.8	20			Y
7-20		7.8	20			Y
7-21		7.8	20			Y
7-22		7.8	20			Y
7-26		7.4	20			Y
7-27		7.5	20			Y
7-28		7.5	20			Y
7-29		7.4	20			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimums?

DISTRIBUTION

PWS ID 4100925

S.W. LINCOLN COUNTY WTR. DIST.

Sample Period: Every 36 months

# of Distribution Samples required: 2

Number of excursions during this Sample Period: 0

(Count the number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.1

Print Name: Zach Forcier

Signature: [signature]

Date: 8-5-22

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381