



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.4				Y
3	7.5				Y
4	7.4	17			Y
5	7.4				Y
6	7.5				Y
7	7.5				Y
8	7.4				Y
9	7.4				Y
10	7.3				Y
11	7.4				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.4				Y
17	7.5				Y
18	7.6	16			Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.4				Y
24	7.5				Y
25	7.4				Y
26	7.5				Y
27	7.5				Y
28	7.4				Y
29	7.5				Y
30	7.5				Y

(No = N = Excursion) Total N's ☒<<Have
minimums
been met
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: 06/23
Month/YearNumber of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)
Is system in compliance? (Y) N

—Reference—

Minimum Water Quality
Parameters as set by State:pH 7.2Print Name: Lyle T ArrantSignature: Lyle T. ArrantDate: 07/05/23

Send to OHD within 10 days after end of sampling period