



## Lead &amp; Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.5				Y
3	7.3				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.6				Y
8	7.6				Y
9	7.7				Y
10	7.7				Y
11	7.7				Y
12	7.6				Y
13	7.6	27			Y
14	7.5				Y
15	7.5				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.5				Y
26	7.5	25			Y
27	7.5				Y
28	7.5				Y
29	7.4				Y
30	7.4				Y

(No = N = Excursion) Total N's ☒<<Have  
minimums  
been met  
for this day?

## ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: 09/23  
Month/YearNumber of excursions\* during this month: 0  
(Count the number of days when any WQP was less  
than the minimum required)Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )  
Is system in compliance? (Y) N

—Reference—

Minimum Water Quality  
Parameters as set by State:

pH 7.2

Print Name: Lyle T. Arrant  
Signature: Lyle T. Arrant  
Date: 10/05/23

Send to OHD within 10 days after end of sampling period