



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.5				Y
3	7.5				Y
4	7.4				Y
5	7.4				Y
6	7.5				Y
7	7.5	30			Y
8	7.5				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.4				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.7				Y
19	7.8				Y
20	7.8	30			Y
21	7.8				Y
22	7.5				Y
23	7.5				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.3				Y
28	7.4				Y
29	7.5				Y
30	7.4				Y
31	7.5				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: 07/24

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? (Y) N

—Reference—

Minimum Water Quality Parameters as set by State:

pH 7.2



Print Name: Lyle T. Grant

Signature: Lyle T. Grant

Date: 08/07/24

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period