



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.5	25			Y
3	7.5				Y
4	7.5				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.5				Y
9	7.5				Y
10	7.4				Y
11	7.4				Y
12	7.5				Y
13	7.6				Y
14	7.6				Y
15	7.6	35			Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.5				Y
21	7.5				Y
22	7.6				Y
23	7.5				Y
24	7.3				Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5	33			Y
29	7.5				Y
30	7.6				Y
31	7.6				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPORT, CITY OF

Sample period: 8/24
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

—Reference—

Minimum Water Quality Parameters as set by State:

pH 7.2



Print Name: Lyle T. Arrant
 Signature: Lyle T. Arrant
 Date: 9-1-24

(No = N = Excursion) Total N's 0