



## Lead &amp; Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.6				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5	32			Y
7	7.5				Y
8	7.5				Y
9	7.6				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.6				Y
14	7.6				Y
15	7.7				Y
16	7.7				Y
17	7.6				Y
18	7.6	30			Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.5				Y
24	7.6				Y
25	7.6				Y
26	7.4				Y
27	7.5				Y
28	7.5				Y
29	7.4				Y
30	7.4				Y
31	7.4				Y

<<Have  
minimums  
been met  
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPORT, CITY OF

Sample period: 10/24  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less  
than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

Is system in compliance? Y N

—Reference—

Minimum Water Quality  
Parameters as set by State:

pH 7.2Print Name: Lyle T. ArrantSignature: Lyle T. ArrantDate: 11/02/24(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4388