

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.5				Y
3	7.4				Y
4	7.5				Y
5	7.4	20			Y
6	7.3				Y
7	7.4				Y
8	7.4				Y
9	7.3				Y
10	7.3				Y
11	7.4				Y
12	7.4				Y
13	7.5				Y
14	7.4				Y
15	7.5				Y
16	7.5				Y
17	7.3				Y
18	7.4	25			Y
19	7.3				Y
20	7.3				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.5				Y
30	7.4				Y

<<Have
 minimums
 been met
 for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPORT, CITY OF

Sample period: April 2025
 Month/Year

Number of excursions* during this month:
 (Count the number of days when any WQP w
 than the minimum required)

Total excursions during the previous 5 mo
 (Over 9 excursions in 6 months is a violation.
 Point and Distribution excursions are cumula
 Is system in compliance? Y/N

—Reference—

Minimum Water Quality
 Parameters as set by State:

pH 7.2



(No = N = Excursion) Total N's 0

Print Name: James Ledbetter

Signature: James Ledbetter

Date: 5-2-25

Send to OHD within 10 days after end of sampli

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) :