

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	30			Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.5				Y
6	7.4				Y
7	7.4				Y
8	7.5				Y
9	7.6				Y
10	7.4				Y
11	7.4				Y
12	7.5				Y
13	7.4				Y
14	7.4	32			Y
15	7.5				Y
16	7.5				Y
17	7.4				Y
18	7.3				Y
19	7.4				Y
20	7.4				Y
21	7.3				Y
22	7.4				Y
23	7.3				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4	28			Y
28	7.4				Y
29	7.4				Y
30	7.5				Y
31	7.3				Y

(No = N = Excursion) Total N's

0

<<Have
minimums
been met
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: MAY 2025
 Month/Year

Number of excursions* during this month:
 (Count the number of days when any WQP wa
 than the minimum required)

Total excursions during the previous 5 mon
 (Over 9 excursions in 6 months is a violation. I
 Point and Distribution excursions are cumulat
 Is system in compliance? Y/ N

—Reference—

Minimum Water Quality
 Parameters as set by State:

pH 7.2



Print Name: James Ledbetter

Signature: James Ledbetter

Date: 6-2-2025

Send to OHD within 10 days after end of samplin

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 7