



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.5	32			Y
10	7.6				Y
11	7.3				Y
12	7.4				Y
13	7.3				Y
14	7.4				Y
15	7.4				Y
16	7.4				Y
17	7.3				Y
18	7.3				Y
19	7.5				Y
20	7.3				Y
21	7.2				Y
22	7.5	30			Y
23	7.6				Y
24	7.5				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.5				Y
29	7.4				Y
30	7.5				Y

<<Have
minimums
been met
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPORT, CITY OF

Sample period: June 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
Is system in compliance? Y N

—Reference—

Minimum Water Quality
Parameters as set by State:

pH 7.2(No = N = Excursion) Total N's 0Print Name: James LedbetterSignature: James LedbetterDate: 7-7-2025

Send to OHD within 10 days after end of sampling p

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-