

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.6				Y
3	7.4				Y
4	7.3				Y
5	7.6	25			Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.5				Y
10	7.6				Y
11	7.6				Y
12	7.5				Y
13	7.6				Y
14	7.5				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6	25			Y
19	7.6				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31	7.6				Y

<<Have  
 minimums  
 been met  
 for this day?

**ENTRY POINT**

**A**

**PWS ID 4100926**

**WALDPOR, CITY OF**

Sample period: July 2025  
 Month/Year

Number of excursions\* during this month: 7  
 (Count the number of days when any WQP was  
 less than the minimum required)

Total excursions during the previous 5 months:  
 (Over 9 excursions in 6 months is a violation. Lead  
 Point and Distribution excursions are cumulative)  
 Is system in compliance? (Y) N

—Reference—

Minimum Water Quality  
 Parameters as set by State:

pH 7.2



Print Name: James Ledbetter  
 Signature: James Ledbetter  
 Date: 8-4-2025

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 7