



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.5	25			Y
9	7.5				Y
10	7.4				Y
11	7.5				Y
12	7.4				Y
13	7.4				Y
14	7.5				Y
15	7.4				Y
16	7.4				Y
17	7.4				Y
18	7.6				Y
19	7.5				Y
20	7.5				Y
21	7.5	28			Y
22	7.4				Y
23	7.4				Y
24	7.5				Y
25	7.5				Y
26	7.4				Y
27	7.4				Y
28	7.5				Y
29	7.5				Y
30	7.4				Y
31	7.5				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: March 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? (Y) N

—Reference—

Minimum Water Quality Parameters as set by State:

pH 7.2



(No = N = Excursion) Total N's 0

Print Name: James Ledbetter

Signature: James Ledbetter

Date: 4-2-2026

Send to OHD within 10 days after end of sampling p

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-