

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.4				Y
3	7.4				Y
4	7.5	18			Y
5	7.4				Y
6	7.4				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.4				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.6				Y
15	7.7				Y
16	7.5				Y
17	7.5				Y
18	7.5	20			Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.5				Y
23	7.5				Y
24	7.5				Y
25	7.6				Y
26	7.4				Y
27	7.6				Y
28	7.5				Y
29	7.4				Y
30	7.5	20			Y
31	7.5				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPORT, CITY OF

Sample period: _____

01/21

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y N

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

RECEIVED

FEB 08 2021

Data Mgmt & Compliance
Drinking Water Program

Print Name: _____

Lyle T. Arvant

Signature: _____

Lyle T. Arvant

Date: 02/02/21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381