

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.4				Y
3	7.5	20			Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.6				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.4	23			Y
16	7.4				Y
17	7.5				Y
18	7.5				Y
19	7.6				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.6				Y
24	7.5				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.5				Y
29	7.5	22			Y
30	7.5				Y
31	7.5				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100926**  
**WALDPOR, CITY OF**

Sample period: 05/21  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? (Y) N

Reference \_\_\_\_\_

Minimum Water Quality Parameters as set by State:

pH 7.2

(No = N = Excursion) Total N's 0

Print Name: Lyle T. Arrant  
 Signature: Lyle T. Arrant  
 Date: 06/07/21

Send to OHD within 10 days after end of sampling period