

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.5				Y
3	7.5	25			Y
4	7.6				Y
5	7.5				Y
6	7.5				Y
7	7.6				Y
8	7.7				Y
9	7.6				Y
10	7.6				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.6				Y
15	7.6				Y
16	7.6	27			Y
17	7.6				Y
18	7.5				Y
19	7.4				Y
20	7.6				Y
21	7.5				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.6				Y
30	7.6	26			Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: _____

11/21

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y N

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: _____

Signature: _____

Date: _____

Lyle T. Grant

12/08/21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period