

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N
j	7.5				Y
2	7.5	17		AND THE PROPERTY OF THE PROPER	Y
3	7.6			A CHESCO STOCK AND THE PROPERTY OF	4
4	7.5				Y
5	7.5				4
6	7.4			-	14
7	7,5				4
8	7.5				14
9	7.6				14
10	7.4				14
11	7.4				Y
12	7.5				14
13	7.6			-	4
14	7.5				14
15	7.6	18		NA TANÀNA MANAGAMBANA	14
16	7.6				14
design de	7.5				14
COUNTY OF STREET, STREET	7.6				Y
19	7.6				14
20	7.4				Y
21	7.5				4
22	7.5				4
23					14
24	7.6				14
25	7.6				14
23 24 25 26 27	7.5				Y
27	7.6				Y
28	7.5	20			Y
93					
65					
Provident Approximate parties				2	1/4

(No = N = Excursion) Total N's

< <have< th=""></have<>
minimums
been met
for this day?

ENTRY POINT A

PWS ID 4100926 WALDPORT, CITY OF

Sample	period:_	02/	22
		Mo	nth/Year

Number of excursions* during this month: 6 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
Is system in compliance? (Y) N

-Reference	

Minimum Water Quality
Parameters as set by State:

pH 7.2

Print Name:	Lyle T. Arrant
Signature:	Lyb I. anant

Date: 03/02/22

Send to OHD within 10 days after end of sampling perio

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-438