



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.5				Y
3	7.4				Y
4	7.5				Y
5	7.5				Y
6	7.5	25			Y
7	7.5				Y
8	7.4				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.4				Y
14	7.2				Y
15	7.6				Y
16	7.5				Y
17	7.5				Y
18	7.6				Y
19	7.5	24			Y
20	7.6				Y
21	7.5				Y
22	7.7				Y
23	7.7				Y
24	7.5				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.7				Y
29	7.5				Y
30	7.6				Y

<<Have
minimums
been met
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: 09/22
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

Is system in compliance? (Y)/N

—Reference—

Minimum Water Quality
Parameters as set by State:

pH 7.2

(No = N = Excursion) Total N's 0

Print Name: Lyle T. Arrant

Signature: Lyle T. Arrant

Date: 10/05/22

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381