



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.5				Y
3	7.6				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.5				Y
8	7.5				Y
9	7.5	25			Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.5				Y
15	7.5				Y
16	7.4				Y
17	7.5				Y
18	7.6				Y
19	7.5				Y
20	7.7				Y
21	7.6				Y
22	7.7	26			Y
23	7.5				Y
24	7.5				Y
25	7.5				Y
26	7.6				Y
27	7.4				Y
28	7.5				Y
29	7.5				Y
30	7.4				Y

<<Have
minimums
been met
for this day?

ENTRY POINT

A

PWS ID 4100926

WALDPOR, CITY OF

Sample period: November 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y/N

—Reference—

**Minimum Water Quality
Parameters as set by State:**

pH 7.2

(No = N = Excursion) Total N's 0

Print Name: Lyle T. Arrant

Signature: Lyle T. Arrant

Date: 12/06/22

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4358