

ID #	Sample Location	pH	Alk	PO4	other	Y/N
wL1	West Linn Public works	8.05	26			Y
wL2	Maxfield Sample station	7.90	25			
wL3	Horton Pump station	7.84	24			
wL4	Rosemont Reservoir	7.91	27			
wL5	1391 Skye Parkway	8.39	27			
wL6	5578 River St	7.92	28			
wL7	Dollar Street S.S.	7.91	30			
wL8	22601-M willamette DR	7.88	25			↓
wL1	West Linn Public works	8.10	40			Y
wL2	Maxfield Sample station	7.86	26			
wL3	Horton Pump station	7.81	27			
wL4	Rosemont Reservoir	7.83	28			
wL5	1391 Skye Parkway	8.34	30			
wL6	5578 River St	7.91	30			
wL7	Dollar Street S.S.	7.88	27			
wL8	22601-M willamette DR	7.83	27			↓

(N = No = Excursion) Total N's 0

<Has sample met the minimums?

### DISTRIBUTION

PWS ID: 41 0 0 9 4 4

System Name: City of West Linn

Sample Period: June 2021  
Month/Year

Sample Frequency: Every 36 months

Distribution Samples required: 7

Number of excursions during this Sample Period = 0  
(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.8

Alk 22.0 (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: Luke Fullington

Signature: *Luke Fullington*

Date: 6-30-2021

Send to Drinking Water Program within 10 days after end of sampling period:  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>