Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
01	West Linn Public Works S.S.	8.72	39			Y
02	Maxfield S.S.	7.95	33			
03	Horton P.S.	7.96	33			
04	Rosemont Reservoir	8.07	34			
05	Skye Pkwy S.S.	8.29	34			
06	River Street S.S.	8.38	28			
07	Dollar Street S.S.	8.30	33			↓
08	Curb Stop Hwy 43 (EPTDS) – Entry Point	8.27	31			
01	West Linn Public Works S.S.	8.73	33			Y
02	Maxfield S.S.	8.24	33			
03	Horton P.S.	8.00	33			
04	Rosemont Reservoir	7.93	30			
05	Skye Pkwy S.S.	8.25	33			
06	River Street S.S.	8.41	39			
07	Dollar Street S.S.	8.13	33			↓
08	Curb Stop Hwy 43 (EPTDS) – Entry Point	8.20	31			↓

6-5-2024

6-11-2024

(N = No = Excursion) **Total N's** Ø

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 0 0 9 4 4

System Name: City of West Linn

Sample Period: June/2024 *Month/Year*

Sample Frequency: every 3 years

Distribution Samples required: 7

Number of excursions during this Sample Period = Ø

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.8	
Alk	22.0	*(Alkalinity)*
PO4		*(Orthophosphate)*
Other		(_____)

Print Name: Steven Kelley

Signature: Steven Kelley

Date: 8-21-2024

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/