

City of Manzanita

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	
1	7.32				Y		
2	7.34				Y		
3	7.36				Y		
4	7.31				Y		
5	7.29				Y		
6	7.34				Y		
7	7.33				Y		
8	7.34				Y		
9	7.28				Y		
10	7.36				Y		
11	7.29				Y		
12	7.27				Y		
13	7.39				Y		
14	7.31				Y		
15	7.29				Y		
16	7.31				Y		
17	7.30				Y		
18	7.31				Y		
19	7.23				Y		
20	7.41				Y		
21	7.39				Y		
22	7.41				Y		
23	7.43				Y		
24	7.42				Y		
25	7.42				Y		
26	7.41				Y		
27	7.30				Y		
28	7.24				Y		
29	7.34				Y		
30	7.36				Y		
31	7.40				Y		
					(No = N = Excursion)	Total N's	0

County: Tillamook Agency: Region 1

ENTRY POINT
EP-C
PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2

SYSTEM NAME: City of Wheeler

SAMPLE PERIOD: July-21
MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameters set for this PWS:

pH 7.2

Print Name: Daniel L. Weitzel
Signature: *Daniel L. Weitzel*
Cert. #: WD1- #7191 / WT2 - # 08183
Date: 6/9/2021
Phone: (503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp