

City of Manzanita

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N | << Have minimums been met for this day? |
|----------------------|------|-----|------|------|-----------|---|
| 1 | 7.39 | | | | Y | |
| 2 | 7.31 | | | | Y | |
| 3 | 7.36 | | | | Y | |
| 4 | 7.42 | | | | Y | |
| 5 | 7.42 | | | | Y | |
| 6 | 7.44 | | | | Y | |
| 7 | 7.42 | | | | Y | |
| 8 | 7.41 | | | | Y | |
| 9 | 7.40 | | | | Y | |
| 10 | 7.44 | | | | Y | |
| 11 | 7.40 | | | | Y | |
| 12 | 7.38 | | | | Y | |
| 13 | 7.48 | | | | Y | |
| 14 | 7.28 | | | | Y | |
| 15 | 7.44 | | | | Y | |
| 16 | 7.34 | | | | Y | |
| 17 | 7.43 | | | | Y | |
| 18 | 7.42 | | | | Y | |
| 19 | 7.38 | | | | Y | |
| 20 | 7.42 | | | | Y | |
| 21 | 7.41 | | | | Y | |
| 22 | 7.47 | | | | Y | |
| 23 | 7.38 | | | | Y | |
| 24 | 7.38 | | | | Y | |
| 25 | 7.40 | | | | Y | |
| 26 | 7.44 | | | | Y | |
| 27 | 7.47 | | | | Y | |
| 28 | 7.32 | | | | Y | |
| 29 | 7.32 | | | | Y | |
| 30 | 7.41 | | | | Y | |
| 31 | 7.34 | | | | Y | |
| (No = N = Excursion) | | | | | Total N's | 0 |

County: Tillamook Agency: Region 1

ENTRY POINT
EP-C
PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2

SYSTEM NAME: City of Wheeler

SAMPLE PERIOD: December-21
MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameters set for this PWS:

pH 7.2

Print Name: Daniel L. Weitzel

Signature: *Daniel L. Weitzel*

Cert. #: WD1- #7191 / WT2 - # 08183

Date: 01/08/2022

Phone: (503) 812-2727

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp