

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N	
1	7.57				Y	
2	7.37				Y	
3	7.32				Y	
4	7.25				Y	
5	7.32				Y	
6	7.42				Y	
7	7.39				Y	
8	7.35				Y	
9	7.27				Y	
10	7.21				Y	
11	7.28				Y	
12	7.22				Y	
13	7.33				Y	
14	7.41				Y	
15	7.41				Y	
16	7.29				Y	
17	7.25				Y	
18	7.24				Y	
19	7.25				Y	
20	7.32				Y	
21	7.27				Y	
22	7.34				Y	
23	7.33				Y	
24	7.38				Y	
25	7.38				Y	
26	7.32				Y	
27	7.32				Y	
28	7.33				Y	
29	7.35				Y	
30	7.38				Y	
1	0.00				-	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT EP-C PWS ID: 4 1 0 0 9 5 2
SYSTEM NAME: <u>City of Wheeler</u>
SAMPLE PERIOD: <u>November-22</u> MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference <p style="text-align: center;">Minimum Water Quality Parameters set for this PWS:</p> pH <input type="text" value="7.2"/>

Print Name:	Daniel L. Weitzel
Signature:	<i>Daniel L. Weitzel</i>
Cert. #:	WD2- #7191 / WT2 - # 08183
Date:	Wednesday, December 7, 2022
Phone:	(503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp