

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.29				Y
2	7.21				Y
3	7.25				Y
4	7.37				Y
5	7.36				Y
6	7.31				Y
7	7.33				Y
8	7.36				Y
9	7.37				Y
10	7.49				Y
11	7.42				Y
12	7.37				Y
13	7.42				Y
14	7.38				Y
15	7.41				Y
16	7.40				Y
17	7.39				Y
18	7.38				Y
19	7.32				Y
20	7.37				Y
21	7.39				Y
22	7.50				Y
23	7.41				Y
24	7.34				Y
25	7.42				Y
26	7.42				Y
27	7.51				Y
28	7.39				Y
29	7.38				Y
30	7.29				Y
31	7.28				Y

<< Have minimums been met for this day?

ENTRY POINT

EP-C

PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2

SYSTEM NAME:

City of Wheeler

SAMPLE PERIOD:

August-24

MONTH / YEAR

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality

Parameters set for this PWS:

pH

Print Name:

Daniel L. Weitzel

Signature:

Daniel L. Weitzel

Cert. #:

WD2- #7191 / WT2 - # 08183

Date:

Sunday, September 8, 2024

Phone:

(503) 368-5347

(No = N = Excursion)

Total N's

0

**Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**