

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.5				Y
3	7.5				Y
4	7.9				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.6				Y
14	7.5				Y
15	7.4				Y
16	7.5				Y
17	7.6				Y
18	7.5				Y
19	7.5				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.6				Y
26	7.4				Y
27	7.5				Y
28	7.6				Y
29	7.5				Y
30	7.5				Y

<< Have minimums been met for this day?

ENTRY POINT

EP-C

PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2

SYSTEM NAME: City of Wheeler

SAMPLE PERIOD: November-24

MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameters set for this PWS:

pH

(No = N = Excursion) Total N's

Print Name: Daniel L. Weitzel

Signature: *Daniel L. Weitzel*

Cert. #: WD2- #7191 / WT2 - # 08183

Date: Monday, December 2, 2024

Phone: (503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp