

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?
1	7.4				Y	
2	7.4				Y	
3	7.3				Y	
4	7.4				Y	
5	7.5				Y	
6	7.3				Y	
7	7.4				Y	
8	7.4				Y	
9	7.3				Y	
10	7.3				Y	
11	7.5				Y	
12	7.4				Y	
13	7.5				Y	
14	7.4				Y	
15	7.4				Y	
16	7.5				Y	
17	7.5				Y	
18	7.4				Y	
19	7.5				Y	
20	7.3				Y	
21	7.4				Y	
22	7.3				Y	
23	7.3				Y	
24	7.3				Y	
25	7.2				Y	
26	7.3				Y	
27	7.2				Y	
28	7.4				Y	
1	0.0				-	
2	0.0				-	
3	0.0				-	

(No = N = Excursion) Total N's **0**

County: Tillamook Agency: Region 1

ENTRY POINT
EP-C
PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2

SYSTEM NAME: City of Wheeler

SAMPLE PERIOD: February-2025
MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality
Parameters set for this PWS:**

pH 7.2

Print Name: Rick Rempfer

Signature: *Rick Rempfer*

Cert. #: D1-144265 / T1-144265

Date: Friday, March 7, 2025

Phone: (503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp