

**OHA / DWP**

Oregon Health Authority

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.6				Y
9	7.6				Y
10	7.5				Y
11	7.3				Y
12	7.5				Y
13	7.5				Y
14	7.6				Y
15	7.7				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.7				Y
26	7.6				Y
27	7.6				Y
28	7.5				Y
29	7.5				Y
30	7.6				Y
	7.6				Y
(No = N : 0 Total N's					<b>0</b>

<< Have minimums been met for this day?

**ENTRY POINT**  
**EP-C**  
**PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2**

---

**SYSTEM NAME:** City of Wheeler

---

**SAMPLE PERIOD:** December-2025  
MONTH / YEAR

**Number of excursions\* during this month:** 0

**(Over 9 excursions in 6 months is a violation.)**  
Entry Point and Distribution excursions are cumulative)

\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameters set for this PWS:**

pH

**Print Name:** Rick Rempfer

**Signature:** *Rick Rempfer*

**Cert. #:** D1-144265 / T1-144265

**Date:** Monday, January 5, 2026

**Phone:** (503) 368-5347

**Send to DHS-DWP within 10 days after end of sampling period to:**  
**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350**  
**Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**