

City of Manzanita

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	
1	7.48				Y		
2	7.51				Y		
3	7.52				Y		
4	7.54				Y		
5	7.37				Y		
6	7.40				Y		
7	7.43				Y		
8	7.38				Y		
9	7.46				Y		
10	7.44				Y		
11	7.44				Y		
12	7.40				Y		
13	7.52				Y		
14	7.42				Y		
15	7.41				Y		
16	7.35				Y		
17	7.39				Y		
18	7.39				Y		
19	7.46				Y		
20	7.40				Y		
21	7.48				Y		
22	7.38				Y		
23	7.41				Y		
24	7.36				Y		
25	7.57				Y		
26	7.40				Y		
27	7.63				Y		
28	7.43				Y		
29	7.36				Y		
30	7.31				Y		
31	7.35				Y		
					(No = N = Excursion)	Total N's	<b>0</b>

County: Tillamook Agency: Region 1

**ENTRY POINT**  
**EP-C**  
**PWS ID: 4 | 1 | 0 | 0 | 9 | 5 | 2**

**SYSTEM NAME:** City of Wheeler

**SAMPLE PERIOD:** March-22  
MONTH / YEAR

**Number of excursions\* during this month:** 0

**(Over 9 excursions in 6 months is a violation.)**  
*Entry Point and Distribution excursions are cumulative)*

*\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameters set for this PWS:**

pH 7.2

**Print Name:** Daniel L. Weitzel

**Signature:** *Daniel L. Weitzel*

**Cert. #:** WD1- #7191 / WT2 - # 08183

**Date:** 2/9/2022

**Phone:** (503) 368-5347

**Send to DHS-DWP within 10 days after end of sampling period to:**  
**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350**  
**Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**