

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	Entry Point		≥Min?	Distribution		≥Min?
	pH	Alk	Y/N	pH	Alk	Y/N
1	7.60		y	7.69		y
2	7.63		y	7.77		y
3	7.55		y	7.37		y
4	7.65	36	y	7.66	36	y
5	7.60		y	7.54		y
6	7.56		y	7.68		y
7	7.56		y	7.59		y
8	7.64		y	7.48		y
9	7.60		y	7.67		y
10	7.51	35	y	7.51	30	y
11	7.65		y	7.57		y
12	7.48		y	0.00		y
13	7.46		y	7.43		y
14	7.36		y	7.69		y
15	7.27		y	7.28		y
16	7.39		y	7.29		y
17	7.25		y	7.55		y
18	7.42	28	y	7.44	28	y
19	7.59		y	7.59		y
20	7.43		y	7.55		y
21	7.37		y	0.00		y
22	7.34		y	7.28		y
23	7.46		y	7.42		y
24	7.47	29	y	7.51	30	y
25	7.53		y	7.61		y
26	7.51		y	7.49		y
27	7.54		y	7.44		y
28	7.60		y	7.45		y
29	7.52		y	7.35		y
30	7.46		y	7.58		y
31						
Total N's			0			0

(NO = N = Excursions)

ENTRY POINT

<<Have minimums been met for this day*? **PWS ID:** 41 0 0 9 5 3

System Name: City of Willamina

Entry Point: A

Sample Period: Nov 2021

Number of excursions during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by OHA

	EP	DIST	
pH	7.2	7.2	
Alk			(Alkalinity)
PO4			(Orthophosphate)
Other			()

Print Name: Justin N. Riggs

Signature: *Justin N. Riggs*

Date: 12/1/2021

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405