

Lead & Copper Rule Corrosion Control

Day	Entry Point			Distribution		
	pH	Alk	Y/N	pH	Alk	Y/N
1	7.42	31	y	7.47	28	y
2	7.55		y	7.59		y
3	7.48		y	7.55		y
4	7.43		y	7.89		y
5	7.49		y	7.52		y
6	7.52		y	7.47		y
7	7.44		y	7.50		y
8	7.36	29	y	7.41	29	y
9	7.43		y	7.35		y
10	7.40		y	7.46		y
11	7.54		y	7.86		y
12	7.51		y	7.76		y
13	7.51		y	7.45		y
14	7.76		y	7.89		y
15	7.61	30	y	7.61	29	y
16	7.47		y	7.65		y
17	7.51		y	7.46		y
18	7.49		y	7.77		y
19	7.47		y	7.53		y
20	7.51		y	7.48		y
21	7.47		y	7.36		y
22	7.48	32	y	7.32	24	y
23	7.53		y	7.89		y
24	7.60		y	7.90		y
25	7.59		y	7.79		y
26	7.59		y	7.80		y
27	7.47		y	7.80		y
28	7.53		y	7.68		y
29	7.54	28	y	7.64	30	y
30	7.50		y	7.31		y
31	7.43		y	7.69		y
Total N's			0	0		

(NO = N = Excursions)

ENTRY POINT

<<Have minimums been met for this day*? **PWS ID:** 41 0 0 9 5 3

System Name: City of Willamina

Entry Point: A

Sample Period: Dec-21

Number of excursions during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by OHA		
	EP	DIST
pH	7.2	7.2
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Justin R. Riggs

Signature: *Justin R. Riggs*

Date: 11/3/2022

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405