

**Lead & Copper Rule Corrosion Control**

Day	Entry Point			Distribution		
	pH	Alk	≥Min?	pH	Alk	≥Min?
1	7.58		y	7.82		y
2	7.60		y	7.69		y
3	7.62	40	y	7.75	40	y
4	7.62		y	7.70		y
5	7.66		y	7.67		y
6	7.63		y	7.65		y
7	7.62		y	7.91		y
8	7.61		y	7.73		y
9	7.61		y	7.65		y
10	7.58		y	7.62		y
11	7.58		y	7.75		y
12	7.62	40	y	7.98	44	y
13	7.58		y	7.75		y
14	7.62		y	7.80		y
15	7.61		y	7.63		y
16	7.63		y	7.71		y
17	7.61		y	7.65		y
18	7.59		y	7.68		y
19	7.59	42	y	7.70	39	y
20	7.62		y	7.93		y
21	7.57		y	7.90		y
22	7.62		y	7.74		y
23	7.55		y	7.59		y
24	7.58	42	y	7.56	40	y
25	7.57		y	7.73		y
26	7.56		y	7.69		y
27	7.45		y	7.41		y
28	7.52		y	7.54		y
29	7.62		y	7.76		y
30	7.45		y	7.46		y
31	7.59		y	7.71		y
<b>Total N's</b>			<b>0</b>	<b>0</b>		

(NO = N = Excursions)

<<Have **ENTRY POINT** minimums been met for this day\*\*?

**PWS ID:** 41 0 0 9 5 3

**System Name:** City of Willamina

**Entry Point:** A

**Sample Period:** August 2020

**Number of excursions during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 0

(Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by OHA**

	EP	DIST	
pH	7.2	7.2	
Alk			(Alkalinity)
PO4			(Orthophosphate)
Other			( )

**Print Name:** Justin R Riggs

**Signature:** *Justin R Riggs*

**Date:** 9/17/2020

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405