

Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	Entry Point		≥Min?	Distribution		≥Min?
	pH	Alk	Y/N	pH	Alk	Y/N
1	7.79		y	7.72		y
2	7.70		y	7.76		y
3	7.72	31	y	7.85	31	y
4	7.75		y	7.88		y
5	7.63		y	7.69		y
6	7.58		y	7.73		y
7	7.59		y	7.58		y
8	7.55		y	7.68		y
9	7.58		y	7.66		y
10	7.59		y	7.78		y
11	7.58	31	y	8.04	33	y
12	7.58		y	8.00		y
13	7.58		y	8.07		y
14	7.58		y	8.01		y
15	7.60		y	7.61		y
16	7.61		y	7.63		y
17	7.58		y	7.69		y
18	7.56	34	y	7.59	35	y
19	7.60		y	7.65		y
20	7.53		y	7.67		y
21	7.52		y	7.61		y
22	7.56		y	7.67		y
23	7.55		y	7.90		y
24	7.69		y	7.91		y
25	7.60	35	y	7.84	36	y
26	7.59		y	7.89		y
27	7.61		y	7.90		y
28	7.62		y	7.88		y
29	7.61		y	7.89		y
30	7.62		y	7.67		y
31	7.65		y	7.65		y
<b>Total N's</b>			<b>0</b>			<b>0</b>

(NO = N = Excursions)

<b>ENTRY POINT</b>	
<<Have minimums been met for this day*?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 2px;">0 0 9 5 3</span> <b>System Name:</b> <u>City of Willamina</u> <b>Entry Point:</b> <u>A</u> <b>Sample Period:</b> <u>May-23</u>

**Number of excursions during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

Minimum Water Quality Parameters as set by OHA		
	EP	DIST
pH	7.2	7.2
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

**Print Name:** Justin R Riggs  
**Signature:** *Justin R Riggs*  
**Date:** 6/2/2023

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405