

Lead & Copper Rule Corrosion Control

Day	Entry Point		≥Min?	Distribution		≥Min?
	pH	Alk	Y/N	pH	Alk	Y/N
1	7.70		y	7.70		y
2	7.66		y	7.77		y
3	7.69		y	8.14		y
4	7.68		y	7.78		y
5	7.70		y	7.30		y
6	7.70		y	8.01		y
7	7.73	36	y	7.71	36	y
8	7.71		y	7.76		y
9	7.73		y	7.82		y
10	7.69		y	7.89		y
11	7.75		y	7.99		y
12	7.76		y	7.80		y
13	7.66		y	7.67		y
14	7.67	39	y	8.02	41	y
15	7.73		y	7.80		y
16	7.68		y	7.90		y
17	7.70		y	7.90		y
18	7.70		y	7.92		y
19	7.70		y	7.70		y
20	7.74		y	7.90		y
21	7.70	41	y	7.74	45	y
22	7.70		y	7.75		y
23	7.75		y	7.79		y
24	7.72		y	7.81		y
25	7.70		y	7.79		y
26	7.75		y	7.75		y
27	7.80		y	7.81		y
28	7.78		y	7.71		y
29	7.68	42	y	7.69	45	y
30	7.73		y	7.76		y
31	7.80		y	8.15		y
Total N's			0	0		

(NO = N = Excursions)

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

<<Have

ENTRY POINT

minimums

been met for

PWS ID:

41

0 0 9 5 3

this day*?

System Name: City of Willamina

Entry Point:

A

Sample Period:

May 2025

Number of excursions during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months:

0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by OHA

EP DIST

pH	7.2	7.2	
Alk	30	30	(Alkalinity)
PO4			(Orthophosphate)
Other			()

Print Name:

Justin R. Riggs

Signature:

Justin R. Riggs

Date:

6/3/25

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.