

## Water Quality Parameter Monitoring Form

## Lead &amp; Copper Rule Corrosion Control

| Day       | Entry Point |     | ≥Min? | Distribution |     | ≥Min? |
|-----------|-------------|-----|-------|--------------|-----|-------|
|           | pH          | Alk | Y/N   | pH           | Alk | Y/N   |
| 1         | 7.82        |     | y     | 7.92         |     | y     |
| 2         | 7.66        |     | y     | 7.88         |     | y     |
| 3         | 7.76        |     | y     | 7.63         |     | y     |
| 4         | 7.80        |     | y     | 7.79         |     | y     |
| 5         | 7.80        |     | y     | 7.82         |     | y     |
| 6         | 7.81        | 43  | y     | 7.99         | 43  | y     |
| 7         | 7.75        |     | y     | 7.88         |     | y     |
| 8         | 7.72        |     | y     | 7.86         |     | y     |
| 9         | 7.67        |     | y     | 7.81         |     | y     |
| 10        | 7.64        |     | y     | 7.74         |     | y     |
| 11        | 7.61        |     | y     | 7.71         |     | y     |
| 12        | 7.63        |     | y     | 7.75         |     | y     |
| 13        | 7.72        | 44  | y     | 7.78         | 45  | y     |
| 14        | 7.72        |     | y     | 7.96         |     | y     |
| 15        | 7.70        |     | y     | 7.99         |     | y     |
| 16        | 7.70        |     | y     | 7.78         |     | y     |
| 17        | 7.68        |     | y     | 7.66         |     | y     |
| 18        | 7.60        | 45  | y     | 7.75         | 46  | y     |
| 19        | 7.66        |     | y     | 7.85         |     | y     |
| 20        | 7.65        |     | y     | 7.65         |     | y     |
| 21        | 7.59        |     | y     | 7.81         |     | y     |
| 22        | 7.58        |     | y     | 7.85         |     | y     |
| 23        | 7.55        |     | y     | 7.91         |     | y     |
| 24        | 7.61        |     | y     | 7.76         |     | y     |
| 25        | 7.63        | 45  | y     | 7.75         | 44  | y     |
| 26        | 7.66        |     | y     | 7.75         |     | y     |
| 27        | 7.63        |     | y     | 7.65         |     | y     |
| 28        | 7.74        |     | y     | 8            |     | y     |
| 29        | 7.75        |     | y     | 7.83         |     | y     |
| 30        | 7.64        |     | y     | 7.94         |     | y     |
| 31        |             |     |       |              |     |       |
| Total N's |             |     | 0     |              |     | 0     |

(NO = N = Excursions)

<<Have minimums been met for this day\*? **PWS ID:** 41 

|   |   |   |   |   |
|---|---|---|---|---|
| 0 | 0 | 9 | 5 | 3 |
|---|---|---|---|---|

**System Name:** City of Willamina

**Entry Point:** A

**Sample Period:** Jun-25

Number of excursions during this month:

0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months:

0

(Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are cumulative)

For OHA use only

## Minimum Water Quality Parameters as set by OHA

|       | EP  | DIST |                  |
|-------|-----|------|------------------|
| pH    | 7.2 | 7.2  |                  |
| Alk   | 30  | 30   | (Alkalinity)     |
| PO4   |     |      | (Orthophosphate) |
| Other |     |      | ( )              |

Print Name:

Signature:

Date:

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405