

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.63	11.60		0.71	y
2	500 adams	7.41	10.80		0.96	y
3	360 maple	7.65	11.10		0.70	y
4	411 c	7.43	20.00		0.79	y
5	945 hill	7.58	15.00		0.86	y
6	710 5th street	7.43	13.10	28	0.85	y
7	115 ne main	7.52	14.00		0.80	y
8	1523 pioneer	7.62	15.20		0.77	y
9	710 5th street	7.61	12.00		0.83	y
10	710 5th street	7.42	13.00		0.79	y
11	411 c	7.31	17.60		0.77	y
12	500 adams	7.44	13.20		0.81	y
13	710 5th street	7.49	16.00	29	0.77	y
14	360 maple	7.45	13.00		0.60	y
15	360 maple	7.47	13.20		0.62	y
16	360 maple	7.54	10.80		0.75	y
17	500 adams	7.44	11.20		1.00	y
18	500 adams	7.40	11.00		1.00	y
19	411 c	7.41	12.70		0.96	y
20	945 hill	7.33	15.40	25	0.89	y
21	582 fir	7.36	13.50		0.77	y
22	500 adams	7.25	13.80		0.98	y
23	360 maple	7.50	10.80		0.66	y
24	411 c	7.49	10.50		0.65	y
25	710 5th street	7.49	11.10		0.90	y
26	481 3rd	7.38	10.40		0.79	y
27	710 5th street	7.46	11.60	28	0.79	y
28	391 yamhill	7.56	11.70		0.84	y
29	500 adams	7.39	9.90		0.94	y
30	360 maple	7.49	9.20		0.76	y
31	500 adams	7.46	8.50		1.02	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: <u>City of Willamina</u> Sample Period: <u>Jan-21</u> Sample Frequency: <u>Every 3 Years</u> Number of Distribution Samples Required: <u>2</u>

Number of excursions during this sample period: 0
(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Hayes
Signature: *Justin R. Hayes*
Date: 2/11/2021

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405